

**ADDENDUM NO. ONE (1)
CITY OF BALDWIN, GEORGIA
PUBLIC WORKS BUILDING
ISSUED JUNE 5, 2023**

RE: PUBLIC WORKS BUILDING
EMI PROJECT No. 17-035
City of Baldwin, Georgia

FROM: ENGINEERING MANAGEMENT, INC.
303 SWANSON DRIVE
LAWRENCEVILLE, GA 30043
Don Baker, P.E.
770-962-1387

TO: PROSPECTIVE BIDDERS

This Addendum forms a part of the Contract Documents and Drawings and modifies the original bidding documents dated May 2023.

The following items of the Contract Documents are modified as part of this Addendum:

Plans

➤ Sheet S1

1. Attached and made a part of the bid documents is a revised Sheet S-1. The revision is to reduce the concrete slab thickness in the shop area to 6 inches. Reinforcement shall be No. 3 rebar at 12" on center each way. The hairpin has been reduced from a No. 5 rebar to a No. 3 Rebar.

END OF ADDENDUM NO. 1