

**ADDENDUM NO. ONE (1)**  
**CITY OF AUBURN**  
**CABOT'S DRIVE ROADWAY IMPROVEMENTS**  
**RFP #21-004**  
**EMI PROJECT NUMBER 21-004**  
**ISSUED MARCH 23, 2020**

---

---

The following items of the RFP are modified as part of this Addendum:

➤ Section VII. Material, Cost, Hours, and Price – Bid Schedule

The Bid Schedule has been revised as follows:

1. Provided a place at the bottom of the page for a company principal to sign and provide a corporate seal.

A revised Bid Schedule is attached.

**Clarifications**

The following are clarifications based on questions received.

1. **The Bid Tab, has a statement at the bottom, stating “Total Price of Project Not to Exceed: \$ \_\_\_\_\_ “. Is this the total from the unit price, or are we to anticipate any unforeseen issue and guess at that, to include?**  
**Response:** This should be the total price from the unit price items above.
2. **What is the work hours on this project?**  
**Response:** 8:00 a.m. to 6:00 p.m. Monday through Friday.
3. **Can the existing asphalt be milled prior to mixing the soil cement?**  
**Response:** Yes, we are okay with the existing asphalt being milled prior to mixing the soil cement.
4. **Has any cores been taken on this roadway and if so can you provide the core report?**  
**Response:** At this time, there have not been any cores taken along the roadway.
5. **Can a Prime Coat bid item be added for the soil cement or should the Prime Coat cost be in the Soil Cement bid item?**  
**Response:** The Prime Coat cost should be included in the Soil Cement bid item.
6. **What is the anticipated NTP for the project?**  
**Response:** If everything comes together with the bids, signed contracts and bonds, I would anticipate a May 1 NTP date.

END OF ADDENDUM NO.1

Receipt of Addendum 1 is hereby acknowledged By: \_\_\_\_\_

Firm Name: \_\_\_\_\_

**VII. MATERIAL COST, HOURS, AND PRICE**

<b>BID SCHEDULE</b>						
<b>City of Auburn Cabot's Drive Roadway Improvements</b>						
<b>LINE NO.</b>	<b>GDOT ITEM</b>	<b>ITEM</b>	<b>QUANTITY</b>	<b>UNIT</b>	<b>UNIT AMOUNT</b>	<b>AMOUNT</b>
0010	150-1000	Traffic Control	1	LS		
0015	301-2160	Soil-Cem Stab Base Crs, 8 in	2,890	SY		
0020	301-5000	Portland Cement	80	TN		
0025	402-3113	Recycled Asphalt Concrete 12.5 mm Superpave, Gp 1 or 2, Incl Bitum Matl & H Lime	318	TN		
0030	413-0750	Bituminous Tack Coat	145	GAL		
<b>BASE BID TOTAL:</b>						

**TOTAL PRICE OF PROJECT NOT TO EXCEED: \$** \_\_\_\_\_

Respectfully Submitted:      Signature of Principal: \_\_\_\_\_

Title: \_\_\_\_\_

Corporate Seal: